

Provisional Availability Calculation for the Period : From 01.02.2023 To 28.02.2023 (Powerlinks' Lines)

a. Intra-regional element - NR

Sl. No.	Element Code	Element Name	Total Available Hours	Duration Of Outage Attributable to Powerlinks (OH)	Attributable to Powergrid & others (exclude the outage system constraints)			Outage not to be taken into consideration			Total Duration Available for Consideration (THM)	NSC	Ckt. km	OHxNSCxCkt kMs	THMxNSCxCkt kMs	Non Availability Factor/Month (NAFM)	Transmission System Availability Factor (TAFM)	Outage Percentage
								NC	Grid Incident /System constraints	Deemed Available								
A	B	C	D	E	F			G	H	--	I=D-G-H	J	K	L=ExJxK	M=IxJxK	N=L/M	O=100-100xNAFM	P=NAFM%
-	-	-	Hours	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Nos.	kms	-	-	-	-	-
Powerlinks Intra-Regional Lines																		
1	PTL400NR15	400KV BLY(PGCIL)-MRT(PGCIL)-I	672:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	672:00:00	2	183.322	0.00	10266.032	0.00	100.00%	0.00%
2	PTL400NR13	400KV BLY(PGCIL)-MRT(PGCIL)-II	672:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	672:00:00	2	183.322	0.00	10266.032	0.00	100.00%	0.00%
3	PTL400NR16	400KV MRT(PGCIL)-MND(PGCIL)-III	672:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	672:00:00	2	47.509	0.00	2660.504	0.00	100.00%	0.00%
3	PTL400NR14	400KV MRT(PGCIL)-MND(PGCIL)-IV	672:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	672:00:00	2	47.509	0.00	2660.504	0.00	100.00%	0.00%
4	PTL400NR09	400KV BLY(UPPCL)-BLY(PGCIL)-I	672:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	672:00:00	2	5.126	0.00	287.056	0.00	100.00%	0.00%
5	PTL400NR10	400KV BLY(UPPCL)-BLY(PGCIL)-II	672:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	672:00:00	2	5.126	0.00	287.056	0.00	100.00%	0.00%
6	PTL400NR07	400KV GKP-LKO-I	672:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	672:00:00	2	245.905	0.00	13770.68	0.00	100.00%	0.00%
7	PTL400NR08	400KV GKP-LKO-II	672:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	672:00:00	2	245.905	0.00	13770.68	0.00	100.00%	0.00%
				0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	5376:00:00			0.00	53968.544	0.00	100.00%	0.00%

Availability of Intra-Regional Powerlinks Lines

100.000%

b. Inter-regional element (ER - NR)

Sl. No.	Element Code	Element Name	Total Available Hours	Duration Of Outage Attributable to Powerlinks (OH)	Attributable to Powergrid & others (exclude the outage system constraints)			Outage not to be taken into consideration			Total Duration Available for Consideration (THM)	NSC	Ckt. kMs.	OHxNSCxCkt kMs	THMxNSCxCkt kMs	Non Availability Factor/Month (NAFM)	Transmission System Availability Factor (TAFM)	Outage Percentage
								NC	Grid Incident /System constraints	Deemed Available								
A	B	C	D	E	F			G	H	--	I=D-G-H	J	K	L=ExJxK	M=IxJxK	N=L/M	O=100-100xNAFM	P=NAFM%
-	-	-	Hours	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Nos.	kms	-	-	-	-	-
Powerlinks Inter-Regional Lines																		
1	PTL400IR05	400KV GKP-MZP-1	672:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	672:00:00	4	260.399	0.00	29164.688	0.00	100.00%	0.00%
2	PTL400IR06	400KV GKP-MZP-2	672:00:00	0:00:00	2:45:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	672:00:00	4	260.399	0.00	29164.688	0.00	100.00%	0.00%
				0:00:00	2:45:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	1344:00:00			0.00	58329.38	0.00	100.00%	0.00%

Availability of Inter-Regional Powerlinks Lines

100.000%

Availability Calculation for the month of Feb' 23 for Powerlink Lines in ER

Element Name	Attributable to PL		Attributable to Others		Act of God/Grid Incident		Outage Under the Category of Deemed available		Ti	TNAi	Wi (SIL*Ckt Km)	Wi(Ti-TNAi)/Ti	100*Wi(Ti-TNAi)/(Ti*Wi)
	Hrs	Mins	Hrs	Mins	Hrs	Mins	Hrs	Min	Hrs	Hrs			
400 KV NSLG-KSNE-I	16	53	294	49	2	2	0	0	672.0	16.88	64088.9	62478.7	97.488
400 KV NSLG-KSNE- II	0	0	226	0	0	0	0	0	672.0	0.00	64088.9	64088.9	100.000
400 KV KSNE-NPRN-I	0	0	194	31	0	0	0	0	672.0	0.00	45343.4	45343.4	100.000
400 KV KSNE-NPRN-II	0	0	177	46	0	0	0	0	672.0	0.00	45343.4	45343.4	100.000
400 KV NPRN-MUZ-I	0	0	0	0	0	0	0	0	672.0	0.00	125706	125705.8	100.000
400 KV NPRN-MUZ-II	0	0	0	0	0	0	0	0	672.0	0.00	125706	125705.8	100.000
220 KV MUZ-KANTI-I	0	0	0	0	0	0	0	0	672.0	0.00	3174.6	3174.6	100.000
220 KV MUZ-KANTI-II	0	0	6	34	0	0	0	0	672.0	0.00	3174.6	3174.6	100.000
	16	53	897	160	2	2	0	0	5376		476625	475015.17	797.488

Availability 0.99662
% Availability 99.662