

**Provisional Availability Calculation for the Period : From 01.03.2024 To 31.03.2024 (Powerlinks' Lines)**

**a. Intra-regional element - NR**

Sl. No.	Element Code	Element Name	Total Available Hours	Duration Of Outage Attributable to Powerlinks (OH)	Attributable to Powergrid & others (exclude the outage system constraints)		Outage not to be taken into consideration			Total Duration Available for Consideration (THM)	NSC	Ckt. km	OHxNSCxCkt kMs	THMxNSCxCkt kMs	Non Availability Factor/Month (NAFM)	Transmission System Availability Factor (TAFM)	Outage Percentage	
							NC	Grid Incident /System constraints	Deemed Available									
A	B	C	D	E	F		G	H	--	I=D-G-H	J	K	L=ExJxK	M=IxJxK	N=L/M	O=100-100xNAFM	P=NAFM%	
-	-	-	Hours	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Nos.	kms	-	-	-	-	-	
Powerlinks Intra-Regional Lines																		
1	PTL400NR15	400kV BLY(PGCIL)-MRT(PGCIL)-I	744:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	744:00:00	2	183.322	0.00	11365.964	0.00	100.00%	0.00%
2	PTL400NR13	400kV BLY(PGCIL)-MRT(PGCIL)-II	744:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	744:00:00	2	183.322	0.00	11365.964	0.00	100.00%	0.00%
3	PTL400NR16	400kV MRT(PGCIL)-MND(PGCIL)-III	744:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	744:00:00	2	47.509	0.00	2945.558	0.00	100.00%	0.00%
3	PTL400NR14	400kV MRT(PGCIL)-MND(PGCIL)-IV	744:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	744:00:00	2	47.509	0.00	2945.558	0.00	100.00%	0.00%
4	PTL400NR09	400kV BLY(UPPCL)-BLY(PGCIL)-I	744:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	744:00:00	2	5.126	0.00	317.812	0.00	100.00%	0.00%
5	PTL400NR10	400kV BLY(UPPCL)-BLY(PGCIL)-II	744:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	744:00:00	2	5.126	0.00	317.812	0.00	100.00%	0.00%
6	PTL400NR07	400kV GKP-LKO-I	744:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	744:00:00	2	245.905	0.00	15246.11	0.00	100.00%	0.00%
7	PTL400NR08	400kV GKP-LKO-II	744:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	744:00:00	2	245.905	0.00	15246.11	0.00	100.00%	0.00%
				0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	5952:00:00			0.00	59750.888	0.00	100.00%	0.00%

Availability of Intra-Regional Powerlinks Lines **100.00%**

**b. Inter-regional element (ER - NR)**

Sl. No.	Element Code	Element Name	Total Available Hours	Duration Of Outage Attributable to Powerlinks (OH)	Attributable to Powergrid & others (exclude the outage system constraints)		Outage not to be taken into consideration			Total Duration Available for Consideration (THM)	NSC	Ckt. kMs.	OHxNSCxCkt kMs	THMxNSCxCkt kMs	Non Availability Factor/Month (NAFM)	Transmission System Availability Factor (TAFM)	Outage Percentage	
							NC	Grid Incident /System constraints	Deemed Available									
A	B	C	D	E	F		G	H	--	I=D-G-H	J	K	L=ExJxK	M=IxJxK	N=L/M	O=100-100xNAFM	P=NAFM%	
-	-	-	Hours	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Nos.	kms	-	-	-	-	-	
Powerlinks Inter-Regional Lines																		
1	PTL400IR05	400kV GKP-MZP-1	744:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	744:00:00	4	260.399	0.00	32289.476	0.00	100.00%	0.00%
2	PTL400IR06	400kV GKP-MZP-2	744:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	744:00:00	4	260.399	0.00	32289.476	0.00	100.00%	0.00%
				0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	0:00:00	1488:00:00			0.00	64578.95	0.00	100.00%	0.00%

Availability of Inter-Regional Powerlinks Lines **100.00%**

**Availability Calculation for the month of Mar'24 for Powerlink Lines in ER**

Element Name	Attributable to PL		Attributable to Others		Act of God/Grid Incident		Outage Under the Category of Deemed available		Ti	TNAi	Wi (SIL*Ckt Km)	Wi(Ti-TNAi)/Ti	100*Wi(Ti-TNAi)/(Ti*Wi)
	Hrs	Mins	Hrs	Mins	Hrs	Mins	Hrs	Min	Hrs	Hrs			
400 KV NSLG-KSNE-I	0	0	0	0	0	0	0	0	744.0	0.00	64088.856	64088.9	100.000
400 KV NSLG-KSNE- II	0	0	0	0	0	0	0	0	744.0	0.00	64088.856	64088.9	100.000
400 KV KSNE-NPRN-I	0	0	0	0	0	0	0	0	744.0	0.00	45343.374	45343.4	100.000
400 KV KSNE-NPRN-II	0	0	0	0	0	0	0	0	744.0	0.00	45343.374	45343.4	100.000
400 KV NPRN-MUZ-I	19	41	0	0	0	0	0	0	744.0	19.68	125705.84	122380.2	97.354
400 KV NPRN-MUZ-II	0	0	0	0	0	0	0	0	744.0	0.00	125705.84	125705.8	100.000
220 KV MUZ-KANTI-I	0	0	0	0	0	0	0	0	744.0	0.00	3174.6	3174.6	100.000
220 KV MUZ-KANTI-II	0	0	0	0	0	0	0	0	744.0	0.00	3174.6	3174.6	100.000
	<b>19</b>	<b>41</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>5952</b>		<b>476625.33</b>	<b>473299.65</b>	<b>797.354</b>

Availability                    0.99302  
**% Availability                99.302**